

McKee and Associates
Architecture and Interior Design

Addendum

No. FOUR Date: 12/15/10

Project: PHYSICAL EDUCATION FACILITIES
FOR MARBURY HIGH SCHOOL
FOR THE AUTAUGA COUNTY
BOARD OF EDUCATION
PRATTVILLE, ALABAMA

PROJECT NO. 10-166
BC # 2010979

A4.1 GENERAL

- A. The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.
- B. Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

A4.2 SPECIFICATIONS – NO CHANGES

A4.3 DRAWINGS

- A. Refer to **Sheet A1.0**:
 - 1) The line posts for all 8'-0" high and 10'-0" high vinyl coated chain link fencing shall be 2 ½" od. To be included in **Proposal "F"**.
 - 2) The temporary fencing shall be included in **Proposal "F"**.

END OF ADDENDUM FOUR

McKee and Associates

631 South Hull Street • Montgomery, Alabama 36104 • Telephone Number (334) 834-9933 • Fax (334) 834-5159